



HUMBOLDT BAY MUNICIPAL WATER DISTRICT

828 Seventh Street • Eureka, California 95501-1114

PO Box 95 • Eureka, California 95502-0095

Office 707-443-5018 Essex 707-822-2918

Fax 707-443-5731 707-822-8245

EMAIL OFFICE@HBMWD.COM

Website: www.hbmwd.com

BOARD OF DIRECTORS

MICHELLE FULLER, PRESIDENT

DAVID LINDBERG, VICE PRESIDENT

J. BRUCE RUPP, SECRETARY-TREASURER

SHERI WOO, DIRECTOR

TOM WHEELER, DIRECTOR

GENERAL MANAGER

JOHN FRIEDENBACH

Humboldt Bay Municipal Water District On-Site Hypochlorite Generation Project Bid Addenda #3

Bidders shall acknowledge receipt of this Addendum in their bid proposal.

This Addendum addresses the following item:

Question

1. Can the design team clarify if an integrator is needed for this system or if the owner is providing their own integration.
 - a. If integration is required can the design team provide specifications for integration.
 - b. If integration is needed can the bid date be extended.

Answer

See Paragraph 1.3.7 of Specification Section 01 01 00 (Summary of Work), which states the following:

"The contractor shall install and connect the OSHG system, including the pump skid and water softener system not used in the temporary chlorination system installed by the District, to the District's existing system after the above steps have occurred. Note that the District will perform the work required for integration of the new OSHG system with the District's existing SCADA system."

END OF ADDENDUM

11/1/24

Date

A handwritten signature in black ink, appearing to read "Dale H. Danvers", written over a horizontal line.

Signature