



**Humboldt Bay Municipal Water District  
12 kV Switchgear Relocation Project  
Bid Addendum #3**

The purpose of this Addendum is to modify the Contract Documents for the subject project. This Addendum shall become part of said Contract Documents.


**Bidders shall acknowledge receipt of this Addendum in their bid proposal.**

This Addendum addresses the following item:

1. Sheet E-601 does not show the existing PG&E metering being demolished, and Sheet E-602 does not show a new metering compartment in the new switchgear lineup. However, other locations in the plans and specifications show the existing metering being demolished and a new metering compartment being installed in the new switchgear lineup. To clarify, the Contractor shall demolish the existing metering and building as shown on Sheet E-101 and shall install a new metering compartment in the new switchgear lineup and IPA as shown on Sheet E-201 and as discussed in the Bid Schedule, Specification Section 01 22 00 (Measurement and Payment), and other relevant locations in the plans and specifications.

END OF ADDENDUM

\_\_\_\_\_  
12/5/19  
Date

  
\_\_\_\_\_  
Signature